



LOAD MANAGEMENT  
METER SOCKET & LCR  
#W77600000

CALL DEA ENERGY SERVICES  
AFTER WIRING IS COMPLETED  
TO SCHEDULE METER INSTALLATION

**NOTES:**

1. METER SOCKET & RECEIVER LOCATED OUTSIDE 4' TO 6' ABOVE GROUND LEVEL. OR ALIGNED WITH EXISTING METER.
2. CONNECTED HEAT LOAD SHALL NOT EXCEED 5KW (20 AMPS).
3. ALL WIRING SHALL MEET THE REQUIREMENTS OF THE NATIONAL ELECTRICAL CODE. (NEC)

DAKOTA ELECTRIC ASSOCIATION		
<b>GUIDE DRAWING</b> <small>THIS DRAWING WAS DEVELOPED FOR A TYPICAL INSTALLATION AND MAY NOT BE APPLICABLE TO ALL INSTALLATIONS CONSULT AN EXPERT FOR FINAL INSTALLATION DESIGN</small>	<b>SUB-METERED ELECTRIC HEAT SINGLE CIRCUIT</b>	
	<small>OWNER</small> <small>ENG. MANAGER</small> <small>DATE</small> 03/26/2014	<small>NO.</small> DIA-10B