

2. METER SOCKET MUST HAVE BYPASS TO SHUNT CT WHEN METER IS REMOVED.

- 3. CT MUST BE GROUNDED AT ELECTRICAL PANEL.
- 4. LABEL OFF PEAK CONTROL BREAKER.
- 5. FURNACE CIRCUIT ALLOWED TO BE SUB-METERED FOR HEAT PUMP INSTALLATIONS ONLY.
- 6. OPTION: INSTALL SEPERATE LCR FOR HEAT PUMP CONTROL.

## **GUIDE DRAWING**

THIS DRAWING WAS DEVELOPED FOR A TYPICAL INSTALLATION AND MAY NOT BE APPLICABLE TO ALL INSTALLATIONS CONSULT AN EXPERT FOR FINAL INSTALLATION DESIGN

SUB METERED - HEAT PUMP BASEBOARD HEAT

CLASS 1 / DIV 1-8

OWNER ENG. MANAGER NO. DIA-302/28/2023