



CALL DEA ENERGY SERVICES  
AFTER WIRING IS COMPLETED TO  
SCHEDULE METER INSTALLATION

TO VEHICLE  
CHARGER (120V)  
OR OUTLET

NEUTRAL (WHITE)

NEUTRAL

TO BRANCH 240V  
CIRCUIT DISCONNECT  
(BREAKER)

NEUTRAL  
WIRE NUT

GND.

NOTES:

1. 240V REQUIRED TO METER SOCKET TO POWER METER.
2. METER SOCKET LOCATED OUTSIDE 4' TO 6' ABOVE GROUND LEVEL. OR ALIGNED WITH EXISTING METER.
3. ALL WIRING SHALL MEET THE REQUIREMENTS OF THE NATIONAL ELECTRICAL CODE. (NEC)

DAKOTA ELECTRIC ASSOCIATION		
GUIDE DRAWING <small>THIS DRAWING WAS DEVELOPED FOR A TYPICAL INSTALLATION AND MAY NOT BE APPLICABLE TO ALL INSTALLATIONS CONSULT AN EXPERT FOR FINAL INSTALLATION DESIGN</small>	METERED-TOU ELECTRIC VEHICLE 120V	
	OWNER DATE	ENG. MANAGER 02/21/14