



CALL DEA ENERGY SERVICES  
AFTER WIRING IS COMPLETED TO  
SCHEDULE METER INSTALLATION

NOTES:

1. METER SOCKET LOCATED OUTSIDE 4' TO 6' ABOVE GROUND LEVEL. OR ALIGNED WITH EXISTING METER.
2. ALL WIRING SHALL MEET THE REQUIREMENTS OF THE NATIONAL ELECTRICAL CODE. (NEC)

DAKOTA ELECTRIC ASSOCIATION		
GUIDE DRAWING		METERED-TOU ELECTRIC VEHICLE 240V
THIS DRAWING WAS DEVELOPED FOR A TYPICAL INSTALLATION AND MAY NOT BE APPLICABLE TO ALL INSTALLATIONS CONSULT AN EXPERT FOR FINAL INSTALLATION DESIGN		
OWNER	ENG. MANAGER	NO.
DATE	02/21/14	DIA-50-240