



LOAD MANAGEMENT
METER SOCKET & LCR
#W77650000

CALL DEA ENERGY SERVICES
AFTER WIRING IS COMPLETED TO
SCHEDULE METER INSTALLATION

NOTES:

1. 240V REQUIRED TO METER SOCKET TO POWER LOAD CONTROL SWITCH AND METER.
2. METER SOCKET & RECEIVER LOCATED OUTSIDE 4' TO 6' ABOVE GROUND LEVEL. OR ALIGNED WITH EXISTING METER.
3. ALL WIRING SHALL MEET THE REQUIREMENTS OF THE NATIONAL ELECTRICAL CODE. (NEC)

| DAKOTA ELECTRIC ASSOCIATION | | |
|--|---|-------------|
| GUIDE DRAWING | METERED-OFF PEAK ELECTRIC VEHICLE 120V | |
| THIS DRAWING WAS DEVELOPED FOR A TYPICAL INSTALLATION AND MAY NOT BE APPLICABLE TO ALL INSTALLATIONS CONSULT AN EXPERT FOR FINAL INSTALLATION DESIGN | | |
| OWNER | ENG. MANAGER | NO. |
| DATE | 02/21/14 | DIA-5EV-120 |