



LOAD MANAGEMENT  
METER SOCKET & LCR  
#W77650000

CALL DEA ENERGY SERVICES  
AFTER WIRING IS COMPLETED TO  
SCHEDULE METER INSTALLATION

**NOTES:**

1. METER SOCKET & RECEIVER LOCATED OUTSIDE 4' TO 6' ABOVE GROUND LEVEL. OR ALIGNED WITH EXISTING METER.
2. ALL WIRING SHALL MEET THE REQUIREMENTS OF THE NATIONAL ELECTRICAL CODE. (NEC)

<b>DAKOTA ELECTRIC ASSOCIATION</b>		
<b>GUIDE DRAWING</b>		METERED-OFF PEAK ELECTRIC VEHICLE 240V LESS THAN 30 AMPS
THIS DRAWING WAS DEVELOPED FOR A TYPICAL INSTALLATION AND MAY NOT BE APPLICABLE TO ALL INSTALLATIONS CONSULT AN EXPERT FOR FINAL INSTALLATION DESIGN	OWNER    ENG. MANAGER	NO.
DATE    06/28/17		DIA-5EV-240